



# FACILITY REPORT

## ENERGY CONSUMPTION & COST SAVINGS REVIEW

Facility:

Winchester, Virginia Mfg. Plant

## Project Summary

---

During the initial meeting with Customer's facility management, our engineers demonstrated the technology with several objectives in mind;

- To reduce the amount of electricity consumed in the Customer plant.
- To reduce their monthly cost of electricity.
- To reduce the maintenance, repair, and replacement costs of the inductive motors used in the plant.

Once an agreement was reached with Customer, our engineers began addressing the needs described above. Our engineers began the engagement by identifying each electrical circuit in the building for preparing the proper installation plan for the facility. Documenting each circuit in the plant for type of load is important in order to lay out the strategic plan for incorporating our current-balancing technology throughout the plant.

- Our engineers have conducted a performance evaluation and technical assessment of the inductive equipment in the building.
- Our engineers then evaluated the engineering data collected in the plant and performed a financial analysis of the information generated during the building assessment.
- Our engineers reviewed the financial projections to determine the rationale for creating a custom installation plan for installing our Power Systems in the facility.

Once an installation plan was devised, our engineers began reviewing the facility-wide installation plan with the appointed electrical contractors. Our engineers and appointed electricians began the installation of our equipment onto the identified circuits in the facility. We completed the installation process for PHASE 1 of 3 PHASES in the plant onto the identified circuits for current balancing of the electrical circuits connected to each of their injection mold equipment in the plant.

Although the Customer project was structured into a 3-PHASE project, the results of PHASE 1 recognized a noticeable improvement in the electricity consumption for the plant. The following case study has been prepared to present the methodologies and scope of the Customer (Winchester, VA) plant project. Our technology solution has produced compelling and measurable results as outlined in this Case Study.

## Project Objectives

---

In order to detail our entire engineering approach, the primary aim of this project was to provide a comprehensive overview of the energy savings and energy management strategies for Customer Commercial Products, Inc.. To better explore the nature of energy management strategies in the study area, the project also investigated the barriers to and the driving forces for the implementation of our proprietary current-balancing technology and engineering protocols, along with calibrated energy efficiency measure.

Specifically, this Case Study was aimed to:

- Study energy efficiency and management strategies/measures undertaken in the Customer (Winchester) plant.
- Study the major energy efficiency barriers and driving forces prevailing in the Customer (Winchester) plant.
- Identify measures that can help reduce the energy usage in the Customer (Winchester) plant.
- Identify measures that can help improve energy management to bridge the present energy efficiency gap.

## Our Methodology for Customer

---

This research analyzed the level of implementation of our Current-Balancing technology and energy management and efficiency in the plant. It provides comprehensive information about the operating characteristics of equipment used and the electrical circuit's power quality condition in the facility derived from both primary and secondary sources from each of the main transformers in the plant.

The technology approach involved a much more scientific approach than traditional power factor correction technologies. The power factor correction approach was originally considered a temporary approach to fixing existing power quality concerns but was never designed as a permanent fix. Before providing an effective solution toward reducing the electrical demand in a facility, a qualified engineer must be able to adhere to a specific protocol designed to identify inefficiencies in an electrical circuit for contributing to the overall reduction in energy usage for saving money on their monthly electric bill.

Our technology leverages current-balancing technique that applies both electrical and RF principles for the purpose of signal tuning at the 60-hertz frequency for improving current-flow under load conditions.

In order to improve efficient current flow for current-balancing at 60-hertz, tuning under load conditions were performed in parallel on each identified circuit of the electrical system. The reactive energy created in the inductive loads was caused by a multitude of factors between the power being supplied and the demand required from the equipment. Higher, but unnecessary reactive energy loads from the equipment have a tendency of amplifying the effects of 3, 5, 7 and 11 harmonic levels causing additional resistance on the line for disrupting current flow within the equipment, resistive loads and the returning power.

Electrical principles and calculations alone only present a narrow view of the overall consumption of energy. Additional RF principles were applied to achieve proper current-balancing at the desired frequency.

PHASE 1 of Customer's projected 3-PHASE project has been completed. In Phase 1, our equipment was installed on specific identified circuits with the results shown in detail on the Comprehensive Energy Saving Report. *(Available on request).*

The methods used in this case study are comprehensive and qualitative, tailored to answer and satisfy both the goals and research questions. The applied technology used in the project employs proprietary tuning technologies capable of balancing current-flow under load conditions, at the 60-hertz frequency, for reducing energy consumption in any 3-phase electrical system.

Our technology hardware and software solutions provided the driving force for ideal energy efficiency implementation.

## Project Scope and Definitions

---

Our approach was to identify the measure of useful energy output versus energy input with the Client, and it consisted of four (4) Levels or identifying factors that were evaluated: Applied Technology, User Equipment, Equipment Operation Efficiency, and Electrical System Performance.

**LEVEL 1: ELECTRICAL SYSTEM PERFORMANCE:** *Electrical System Performance is the electrical system measure of energy efficiency which is determined by external but deterministic system indicators such as energy usage, production, cost, energy sources, environmental impact and technical indicators amongst others.*

**LEVEL 2: EQUIPMENT OPERATION EFFICIENCY:** *Equipment Operation efficiency is a system-wide measure which is evaluated by considering the proper coordination of different system components. This coordination of system components consists of the physical, time, and human coordination parts. Operation efficiency has the following indicators: physical coordination indicators (sizing and matching); time coordination indicator (time control); and human coordination.*

**LEVEL 3: USER EQUIPMENT:** *User Equipment efficiency is a measure of the energy output of isolated individual energy equipment with respect to given technology design specifications. The equipment efficiency is usually considered being separated from the system and having little interactive effect to other equipment or system components. Equipment efficiency is evaluated by considering the following indicators: capacity; specifications and standards; constraints; and maintenance. Equipment efficiency is specifically characterized by its standardization and constant maintenance.*

**LEVEL 4: APPLIED TECHNOLOGY:** *Applied Technology for energy efficiency is a measure of efficiency of energy conversion, processing, transmission, and usage; and it is often measured by natural laws such as the energy conservation law. Applied Technology efficiency is often evaluated by the following indicators: feasibility; lifecycle cost and return on investment; and coefficients in the conversing/ processing/transmitting rate.*

Our technology and software solution was a deciding factor to equipment, operation, and performance efficiencies. The deterministic relationships between each further decomposed our 4-Level approach to energy efficiency.


## Project Activities

---

### Bill Analytics

Our proposed energy management program consisted of three processes: energy auditing, energy targeting, and energy planning to begin. We have deployed Bill Analytics process to profile energy consumption and to identify the energy saving opportunities in the plant. Through this process, a rough objective or target such as possible percentage of energy savings or energy efficiency improvement was figured out. The process to determine such a reasonable energy efficiency improvement target is called energy targeting as used in our Bill Analytics. The Bill Analytics and planning process focused on the detailed energy efficiency improvement plans and it included energy policy support, organization structures and implementations. There were no clear-cut boundaries among energy auditing, energy targeting and energy planning since this approach was customized for Customer, depending on their electricity usage and size of facility. Below is the actual Bill Analytic generated from Customer's electric bill for establishing a project 'baseline' for the facility.

**Figure 1: Actual Customer Bill Analytic**




## Walk-thru and Engineering Evaluation

Our 'Walk-Through' and Engineering Evaluation is a complete energy evaluation process and serves as a guide for preparing the most optimum energy saving and energy efficiency program for Customer. Our complete engineering evaluation was structured into four levels: conceptual level, active level, technical level, and engineering level.

- **CONCEPTUAL LEVEL:** The conceptual level energy management is characterized by 'identification' as most of the activities involved are simple but effective identification which can be roughly analogized as the '80–20' rule implying a 20% effort with a 80% savings in the areas of Customer's electric bill where our technology can be most effective. This kind of identification is often finished by our Certified Project Manager through analyzing the energy system components and energy consumption utility data, even without adding more meters for data collection and thorough data statistics and analysis.
- **ACTIVE LEVEL:** The active level of energy management implies that further effort other than the '80–20' rule must be applied, and often existing energy data may not be enough and additional metering is needed. After collecting enough data, the previously established conceptual energy management strategies will be improved and validated, therefore, this stage is featured by 'validation'.
- **TECHNICAL LEVEL:** The technical level of energy management is featured by the implementation of the initiatives and the verification of the claimed energy savings that is included in our hardware and software technology solution; system retrofitting, automation and control; metering; creating a baseline; monitoring, evaluating, calculating energy usage; and verifying saving targets.
- **ENGINEERING LEVEL:** The engineering level of energy management involves advanced energy system modelling, benchmarking/baselining, and optimization. The engineering level in its content may overlap with the technical level at the strategic level, but it is often used to provide a technical viability analysis and circuit identification for the Customer's electrical system. Making dedicated engineering comparisons, combinations, and optimization of technical solutions may be included in this level.

## Installation Process

Before preparing for the installation process, our engineers determined specific circuits in the facility and the proportionate loads that make up the total load consumption of the facility. The Figure 2 chart represents the approximate load consumption measured for Customer, Winchester, Virginia plant. The Injection Molding Equipment in the facility represents approximately 92% of the total load consumption. Our Energy Management Solution (PHASE 1) was primarily focused on the specific circuits encompassing the injection mold equipment.




## Post Installation Meeting

The post installation metering process was performed on each identified circuit after the installation and current-balance process was completed in the Customer (Winchester) facility. (See *Comprehensive Engineering Report for complete details and metering data*)

## Final Engineering Report Preparation and Evaluation

Following the results of energy data analysis, installation and Post Installation Metering, **Figure 3** is obtained to show the payback periods and the corresponding percentage savings of a 'Before' and 'After' for energy consumption resulting from Customer's facility-wide retrofit of our technology hardware and software solutions. For the purpose of financial viability, Customer prioritizes the implementation of the initiatives with payback periods not exceeding 15-months. **Figure 3** and **Figure 3a** below illustrates a 14.35% reduction in kilowatt hour usage (kWh).






Figure 3a: Shenandoah Meter Data Chart

Our hardware equipment and software solution are the main technology used in the program and are the relevant items purchased and installed. Listed below are the identified circuits for the Customer Project. In **Figure 3**, each circuit has been meter tested for Peak Amp Draw ‘Before’ and ‘After’, on each identified circuit in the facility. The measurements below are calculated against the ‘Original Peak Amp Draw’ from the original client’s electric bill.

**Figure 3: Circuit Amp Draw Measurement**

Traced Switch Gear	Mach ID Circuit #	(BEFORE) Peak Amp Draw	(AFTER) Peak Amp Draw	XECO400	XECO600	Amp Savings
16	M01	497.31	441.72	0	2	55.59
16	M02	188.02	161.60	0	2	26.42
16	M03	207	178.58	0	1	28.42
16	M04	376	329.98	0	1	46.02
16	M05	186	161.09	0	1	24.91
16	M06	188.02	163.12	0	1	24.90
16	M07	192	167.89	0	1	24.11
16	M08	130.2	112.81	2	0	17.39
16	M09	225	169.51	0	1	55.49
16	M10	254.6	224.53	0	1	30.07
15	M11	315	277.91	0	2	37.09
9	M12	319.45	291.96	0	2	27.49
13	M13	252.6	211.71	0	1	40.89
12	M14	277.68	245.46	0	1	32.22
17	M15	428.19	384.80	0	2	43.39
16	M16	376.1	336.72	0	1	39.38
12	M17	240	208.48	0	1	31.52
17	M18	483.2	443.04	0	2	40.16
17	M19	288	246.96	0	1	41.04

13	M20	324.58	295.01	0	1	29.57
3	M21	306.5	276.58	0	1	29.92
12	M22	267	239.98	0	1	27.02
17	M23	368	319.76	0	1	48.24
17	M24	271	239.60	0	1	31.40
17	M25	386.45	341.50	0	1	44.95
17	M26	386	354.63	0	1	31.37
3	M27	395	338.75	0	2	56.25
16	M28	233	211.71	0	1	21.29
18	M29	602.3	543.57	0	2	58.73
1	M30	431	384.80	0	2	46.20
15	M31	236	213.15	0	1	22.85
15	M32	481	435.90	0	2	45.10
18	M33	255	236.14	0	1	18.86
0	M34	348	293.68	0	1	54.32
4	M35	282	243.45	0	2	38.55
5	M36	342	288.87	0	2	53.13
6	M37	412.3	376.02	0	1	36.28
6	M38	330	296.10	0	1	33.90
11	M39	329	282.32	0	1	46.68
5	M40	423	370.27	0	2	52.73
9	M41	145	121.96	0	1	23.04
10	M42	284.62	256.79	0	1	27.83
10	M43	224	172.35	0	1	51.65
9	M44	318.46	289.71	0	1	28.75
9	M45	507	435.82	0	2	71.18
10	M46	294.2	252.43	0	2	41.77
15	M47	623	572.22	0	3	50.78
15	M48	492	446.34	0	3	45.66
15	M49	765.1	677.77	0	3	87.33
15	M50	538	419.47	0	3	118.53
15	M51	617	544.75	0	3	72.25
10	M52	758	672.40	0	5	85.60
10	M53	412	362.84	0	3	49.16
10	M54	627	444.21	0	4	182.79
5	M55	64.3	48.65	2	0	15.65
1	M56	63.34	48.65	2	0	14.69
10	M57	117.6	87.93	3	0	29.67
17	M58	96.27	81.43	2	0	14.84
17	M59	108	81.43	2	0	26.57
0	M60	66.5	59.51	2	0	6.99
17	M61	66.5	58.12	2	0	8.38
10	M62	88.4	68.43	3	0	19.97

0	M63		0.00	0	0	0
0	M64		0.00	0	0	0
0	M65		0.00	0	0	0
0	M66		0.00	0	0	0
0	M67		0.00	0	0	0
0	M68		0.00	0	0	0
0	M69		0.00	0	0	0
0	M70		0.00	0	0	0
0	M71		0.00	0	0	0
0	M72		0.00	0	0	0
0	M73		0.00	0	0	0
0	M74		0.00	0	0	0
0	M75		0.00	0	0	0
0	M76		0.00	0	0	0
0	M77		0.00	0	0	0
0	M78		0.00	0	0	0
0	M79		0.00	0	0	0
0	M80		0.00	0	0	0
0	M81		0.00	0	0	0
0	M82		0.00	0	0	0
0	M83		0.00	0	0	0
16	M84	2341.40	2195.76	0	2	145.64
0	M85		0.00	0	0	0
0	M86		0.00	0	0	0
<b>Original Peak Amp Draw</b>			<b>NEW Peak Amp Draw</b>			<b>Total Amp Draw Savings</b>
<b>20,110</b>			<b>17,397</b>			<b>2,713</b>

**Note:** Circuits M63 – M83 and Circuits M85 – M86 were not addressed in the Case Study which represents additional circuits and Switch Gears in the facility that will be included in a future installation.

**Figure 5** represents each Identified Trace Circuits for the Xeco Project and includes the proportionate share breakdown of each circuit, for totaling the facility’s entire electrical circuit.

**Figure 5; Identified Trace Circuits**

Circuit (Switch Gear)	Identifier	% Amp Draw		Circuit (Switch Gear)	Identifier	% Amp Draw	
	(Trace ID)	(Facility)	Reduction		(Trace ID)	(Facility)	Reduction
16	M01	2.47%	11.18%	0	M34	1.73%	15.61%
16	M02	0.93%	14.05%	4	M35	1.40%	13.67%
16	M03	1.03%	13.73%	5	M36	1.70%	15.54%
16	M04	1.87%	12.24%	6	M37	2.05%	8.80%
16	M05	0.92%	13.39%	6	M38	1.64%	10.27%
16	M06	0.93%	13.24%	11	M39	1.64%	14.19%
16	M07	0.95%	12.56%	5	M40	2.10%	12.47%
16	M08	0.65%	13.36%	9	M41	0.72%	15.89%
16	M09	1.12%	24.66%	10	M42	1.42%	9.78%
16	M10	1.27%	11.81%	10	M43	1.11%	23.06%
15	M11	1.57%	11.77%	9	M44	1.58%	9.03%
9	M12	1.59%	8.61%	9	M45	2.52%	14.04%
13	M13	1.26%	16.19%	10	M46	1.46%	14.20%
12	M14	1.38%	11.60%	15	M47	3.10%	8.15%
17	M15	2.13%	10.13%	15	M48	2.45%	9.28%
16	M16	1.87%	10.47%	15	M49	3.80%	11.41%
12	M17	1.19%	13.13%	15	M50	2.68%	22.03%
17	M18	2.40%	8.31%	15	M51	3.07%	11.71%
17	M19	1.43%	14.25%	10	M52	3.77%	11.29%
13	M20	1.61%	9.11%	10	M53	2.05%	11.93%
3	M21	1.52%	9.76%	10	M54	3.12%	29.15%
12	M22	1.33%	10.12%	5	M55	0.32%	24.34%
17	M23	1.83%	13.11%	1	M56	0.31%	23.19%
17	M24	1.35%	11.59%	10	M57	0.58%	25.23%
17	M25	1.92%	11.63%	17	M58	0.48%	15.41%
17	M26	1.92%	8.13%	17	M59	0.54%	24.60%
3	M27	1.96%	14.24%	0	M60	0.33%	10.51%
16	M28	1.16%	9.14%	17	M61	0.33%	12.61%
18	M29	3.00%	9.75%	10	M62	0.44%	22.59%
1	M30	2.14%	10.72%				
15	M31	1.17%	9.68%				
15	M32	2.39%	9.38%				
18	M33	1.27%	7.40%				

## Real-Time “Startup” Baseline Monitoring of Project

**Figure 6** is a Baseline Monitor designed for calculating a ‘real-time guide to the Project Engineer for tracking the results of the XECO project. The energy consumption indicator for the Customer plant is considered, and a result of 13.52% total energy saving against the established baseline of 11.25% after the implementation of the XECO hardware and software technology

*Figure 6: Customer Baseline Monitor* solution. The ‘Baseline Monitor’ is based on the calculated amp draw from the Customer Electric Bill compared to the actual amp draw test of the circuit and should not be confused with the actual ‘before’ and ‘after’ meter test of the circuit.

BASELINE MONITOR FROM BILL ANALYTIC		
Amp Draw	BASELINE	Startup
XECO Savings	EXCEEDED BY	Baseline
13.52%	2.27%	11.25%

**Figure 5** Identifies the ‘real-time’ values used by the Project Engineer for tracking results derived from the XECO. A review of the energy bill established a base line value of 11.25%. Implementation of the XECO hardware and software technology resulted in an additional 2.27% increase savings value of 13.52%. The saving values are based on calculated kW reading from the electric bill with ‘real-time’ kW readings.

The operational efficiency has been improved in many aspects. For example, the plant’s injection molding equipment has been better tuned to the electrical system during operation. Each identified circuit includes a load from each injection molding machine in the Customer plant, since the majority of load in the facility is derived from such equipment.

In **Figure 7**, Identified Circuits are labelled as M01 – M62. Each circuit has been measured for energy efficiency using a Dent ElitePRO XC Power Meter/Data Logger and Current Transformers (CT’s). Measurements include ‘Before’ and ‘After’ results of Kilowatts, Kilowatt Peaks, Kilowatt-Hours, Kilovolt Amps, Kilovolt Amp/Reactive, Power factor, Amps and Voltage. **(Meter calibrated on August 08, 2013. Calibration documents available upon request)**

**Figure 7; Installation Check and Balance Performance Chart After XECO Installation**

Installation Check and Balance					
SG #	Trace Circuit	Performance	Savings	Status	Load in Project
16	M01	Below Baseline	11.18%	{Add XECO}	2.473%
16	M02	Approved	14.05%	Complete	0.935%
16	M03	Approved	13.73%	Complete	1.029%
16	M04	Approved	12.24%	Complete	1.870%
16	M05	Approved	13.39%	Complete	0.925%
16	M06	Approved	13.24%	Complete	0.935%
16	M07	Approved	12.56%	Complete	0.955%
16	M08	Approved	13.36%	Complete	0.647%
16	M09	Approved	24.66%	Complete	1.119%
16	M10	Approved	11.81%	Complete	1.266%
15	M11	Approved	11.77%	Complete	1.566%
9	M12	Below Baseline	8.61%	{Add XECO}	1.589%
13	M13	Approved	16.19%	Complete	1.256%
12	M14	Approved	11.60%	Complete	1.381%
17	M15	Below Baseline	10.13%	{Add XECO}	2.129%
16	M16	Below Baseline	10.47%	{Add XECO}	1.870%
12	M17	Approved	13.13%	Complete	1.193%
17	M18	Below Baseline	8.31%	{Add XECO}	2.403%
17	M19	Approved	14.25%	Complete	1.432%
13	M20	Below Baseline	9.11%	{Add XECO}	1.614%
3	M21	Below Baseline	9.76%	{Add XECO}	1.524%
12	M22	Below Baseline	10.12%	{Add XECO}	1.328%
17	M23	Approved	13.11%	Complete	1.830%
17	M24	Approved	11.59%	Complete	1.348%
17	M25	Approved	11.63%	Complete	1.922%
17	M26	Below Baseline	8.13%	{Add XECO}	1.919%
3	M27	Approved	14.24%	Complete	1.964%
16	M28	Below Baseline	9.14%	{Add XECO}	1.159%
18	M29	Below Baseline	9.75%	{Add XECO}	2.995%
1	M30	Below Baseline	10.72%	{Add XECO}	2.143%
15	M31	Below Baseline	9.68%	{Add XECO}	1.174%
15	M32	Below Baseline	9.38%	{Add XECO}	2.392%
18	M33	Below Baseline	7.40%	{Add XECO}	1.268%
0	M34	Approved	15.61%	Complete	1.731%
4	M35	Approved	13.67%	Complete	1.402%
5	M36	Approved	15.54%	Complete	1.701%

**Figure 7; Installation Check and Balance Performance Chart After XECO Installation**

Installation Check and Balance						
SG #		Trace Circuit	Performance	Savings	Status	Load in Project
6		M37	Below Baseline	8.80%	{Add XECO}	2.050%
6		M38	Below Baseline	10.27%	{Add XECO}	1.641%
11		M39	Approved	14.19%	Complete	1.636%
5		M40	Approved	12.47%	Complete	2.103%
9		M41	Approved	15.89%	Complete	0.721%
10		M42	Below Baseline	9.78%	{Add XECO}	1.415%
10		M43	Approved	23.06%	Complete	1.114%
9		M44	Below Baseline	9.03%	{Add XECO}	1.584%
9		M45	Approved	14.04%	Complete	2.521%
10		M46	Approved	14.20%	Complete	1.463%
15		M47	Below Baseline	8.15%	{Add XECO}	3.098%
15		M48	Below Baseline	9.28%	{Add XECO}	2.447%
15		M49	Approved	11.41%	Complete	3.805%
15		M50	Approved	22.03%	Complete	2.675%
15		M51	Approved	11.71%	Complete	3.068%
10		M52	Approved	11.29%	Complete	3.769%
10	M53	Approved	11.93%	Complete		2.049%
10	M54	Approved	29.15%	Complete		3.118%
5	M55	Approved	24.34%	Complete		0.320%
1	M56	Approved	23.19%	Complete		0.315%
10	M57	Approved	25.23%	Complete		0.585%
17	M58	Approved	15.41%	Complete		0.479%
17	M59	Approved	24.60%	Complete		0.537%
0	M60	Below Baseline	10.51%	{Add XECO}		0.331%
17	M61	Approved	12.61%	Complete		0.331%
10	M62	Approved	22.59%	Complete		0.440%
<b>Average % Amp Load Savings per Install:</b>				<b>12.08%</b>		<b>100.00%</b>

NOTE: Due to a fixed budget for the project, the 'Add XECO' indicator above shows circuits that could use additional tuning. However, the baseline for the project has been met, but if additional tuning were applied, additional savings would be achieved.

**Figure 8** illustrates a summary snapshot of calculated measurements performed on identified circuits for PHASE 1 Project in the Customer Commercial Products, Inc. (Winchester, Virginia) plant. The following calculated results are as follows;

	<b>Xeco Energy Efficiency Results</b>			
	<b>Before</b>	<b>After</b>	<b>Savings</b>	<b>Savings (%)</b>
<b>Amp Draw:</b>	<b>22,451</b>	19,739	2,713	12.08%
<b>kVA Demand: kVAR</b>	<b>9,356.6</b>	8,606.5	750.1	8.02%
<b>Reactive:</b>	<b>5,598.8</b>	3,979.4	1,619.4	28.92%
<b>Power Factor Efficiency:</b>	<b>0.718</b>	0.795	0.077	10.65%
<b>kW Peak Supply:</b>	<b>10,597</b>	9,317	1,280	12.08%
<b>kWh Consumption:</b>	<b>5,331,787</b>	4,688,503	643,284	12.07%
<b>** CO2 (Metric Tons):</b>	<b>45,133</b>	39,687	5,445	12.07%

**Figure 8: PHASE 1 'Snapshot' Results of Customer Project**


The calculated results for the Customer Energy Management Project exceeded the baseline of 11.25% energy saving by +.83% or 12.08%. Due to the reduction in energy consumption for Customer (Winchester, VA) plant, there are additional benefits besides 'energy savings' that should be noted and is listed below.

- *Due to the reduction of heat on the line and in the equipment from the reduced resistance levels and less reactive energy, Customer will experience less costs for maintenance on the equipment directly connected to the identified circuits for current-balancing as a result from less 'Start-up' loads and less heat during operation.*
- *Due to the reduced harmonic levels on Level 3, 5, 7 and 11, Customer will experience better lighting efficiencies as electronic ballast and DC circuits in the plant are less compromised.*
- *Due to the improved current flow of the electrical system, Customer will experience less heat as well as better efficiency levels between the primary and secondary from the plants Switch Gear Transformers.*
- *Customer has reduced the Carbon Footprint (CO2 Emissions) in the plant by 81.76 metric tons of carbon emissions.*

## Monthly Energy Consumption and Billing Comparisons

Billing comparisons for energy efficiency projects represent an important part in measuring the results for Customer. **Figure 9** illustrates the metered results from our Hardware and Software Protocol Solution compared to Customer’s monthly electric bill.

**Figure 9; Comparison of Actual Electric Bills;**




Bill vs. Meter Savings Comparison	
* Shenandoah	** Our Solution
\$42,273.93	\$52,750.80

**\*Reference: Shenandoah Electric Bill (Available upon request) \*\* Our 'Comprehensive Engineering Report' is available upon request.**

Note: It was suggested to Shenandoah that their meter may need to be calibrated or that there may be a loose connection on one of the CT's for the meter.

Figure 10 below illustrates the comparison of Customer's 'Run-time Hours' and KWH used



**\*\*NOTE: Customer (Winchester) plant operates at full capacity 24 hours per day.**

**Customer Commercial Products, Inc. (Winchester, VA plant) Project STEPS.**

The Customer energy efficiency project has been further designed into three (3) STEPS:

**STEP 1:** Completed

**STEP 2:** Proposed Switch Gear to further improve energy efficiency.

**STEP 3:** Continued monitoring of the plant's electricity consumption and continued interaction with Customer's electricity provider.

NOTE: For **STEP 2**, it is recommended that additional work be done on each Switch Gear in the facility to better tune and balance between line and transformer for even better energy efficiency. **Figure 11** illustrates a test on Customer's Switch Gear #16 and has performed the effects of a completely balanced circuit under load conditions. It is anticipated that a **STEP 2** will include the remaining 17 Switch Gears.

Calculated 'Full-Facility' Analysis - Equipment: Switch Gear #16		
CUSTOMER NAME: Rubbermaid Commercial Products, Inc.		
Kilowatt Hours was REDUCED by:	10.0%	kWH Cost Metered
kVA (Demand) was REDUCED by:	6.9%	Power Quality Test Metered
kVAR (Reactive Energy) was REDUCED by:	65.3%	Power Quality Test Metered
Power Factor (Efficiency) was IMPROVED by:	19.2%	Power Quality Test Metered
Amperage (Load Consumption) was REDUCED by:	6.9%	Power Quality Test Metered
CO2 Emission (Carbon Footprint) was REDUCED by:	0.00	Metric Tons per Year
PROVIDER NAME: Shenandoah Valley Elec Coop		
PROVIDER'S KW SUPPLY REDUCED by:	120	Kilowatts (KW)

**Figure 11: Summary Analysis from Switch Gear #16 Test Report**

## Customer (Winchester, VA) plant Carbon Emission Reduction.

As a result of reducing the electricity consumption in the Customer facility, additional benefits are also achieved resulting in reduced Carbon (CO<sub>2</sub>) Emissions in the plant. **Figure 12** illustrates the current CO<sub>2</sub> reduction results in the Customer plant. **(A comprehensive CO<sub>2</sub> report is available upon request)**




Figure 12: Carbon Emission Reduction Chart

## 30-Day Facility Test with ITRON Sentinel Form 5S KVA Meter (Utility Co.)

A scheduled 30-Day facility test was conducted to determine the specific level of kilowatt reduction for equipment identified throughout the facility with our technology installed. The meter used for the test was Customer's fixed ITRON Sentinel Form 5S (45S) meter, Serial Number 53-120-705. This meter has been permanently installed and used by Shenandoah Valley Electric Cooperative to measure the total electricity consumption in the facility each month in order to calculate the electric bill. The meter is accurate plus or minus 2 percent as mandated by ANSI STD> C-12.1-8.1.3.3. On April 29, 2014, the meter was inspected and tested for calibration by Reliable Meter Services, Rock Hill, South Carolina. The average registration of the meter series test is 99.96 percent.

Prior to the test, Our engineer inspected each of our device to insure that each device was 'ON' and correctly operating as designed. The full-facility test began with our equipment turned 'ON'. Our equipment remained 'ON' for 23 days before being turned 'OFF' for the last 7 days of the month. Subsequently all of our equipment was turned 'OFF' in the Customer facility in order to determine how much the load would increase in the facility as measured by the meter supplied by the utility company (Shenandoah Valley Electric Cooperative).

Shenandoah Valley Electric Cooperative (Metering Department) supplied detailed metering data consisting of Kilowatt and KVAR meter readings measured in 15-minute intervals. There were 2,880 15minute 'snapshots' collected from the ITRON meter. The results of the 30-Day test indicate the Kilowatt consumption in the facility had increased by 5.19% and the

KVAR had increased by 17.34% as a result of turning our equipment 'OFF' during the last 7 days of the month.

**Figure 13** below is a chart that has been prepared from the data collected by the meter supplied by Shenandoah Valley Electric Cooperative (Customer’s Electricity Provider) to illustrate the results of the 30day test.




Figure 13: ITRON Facility Meter Data - 7-Day Test Results Chart

The kilowatt average per each 15-Minute ‘Snapshot’ during the first 23 days (**Our Equipment ‘ON’**) was 9,621 kW compared to 10,148 kW during the last 7 days (**Our Equipment ‘OFF’**). Turning the equipment ‘OFF’ resulted in a kilowatt average increase of 527 kilowatts every 15-minutes or an increase of 5.47%.

The kVAR average per each 15-Minute ‘Snapshot’ during the first 23 days (**‘ON’**) was 6,431 kVAR compared to 7,780 kVAR during the last 7 days (**‘OFF’**). Turning our equipment ‘OFF’ resulted in a kVAR average increase of 1,349 kVAR every 15-minutes or an increase of 20.97%.

In **Figure 14**, Customer Commercial Products received the monthly electric bill. The monthly electric bill indicates that both the KW Peak and KVAR Peak was recorded at their highest Peaks the day after the Xeco units were turned ‘OFF’, or as indicated on the bill.




Figure 14: Customer Electricity Consumption Data from Electric Bill

The kilowatt PEAK during the first 23 days (**Our Equipment 'ON'**) was recorded at 10,498 kW compared to 10,814.40 kW during the last 7 days (**Our Equipment 'OFF'**). Turning the equipment 'OFF' resulted in a kilowatt PEAK increase of 316.4 kilowatts or an increase of 3%. The KVAR PEAK during the first 23 days (**Our Equipment 'ON'**) was recorded at 7,520 kVAR compared to 8,667 kVAR during the last 7 days (**Our Equipment 'OFF'**). Turning the equipment 'OFF' resulted in a kVAR increase of 1,147 kVAR or an increase of 15.25%.

## CONCLUSION

The Energy Management Program designed for Customer (Winchester plant) was very comprehensive and covered most of the important aspects in energy efficiency using proprietary current balancing technology and a customized engineering protocol to specifically measure the results. Under our complete engineering framework, we were able to improve the performance of the energy management program at the Winchester plant.

This paper provides information and insight into our Technology and the performance of the Energy Management Solution program installed at Customer (Winchester plant) from a comprehensive, 4-Level engineering and analysis approach. This approach defined three criteria for the sustainability of a facility-wide energy program: organizational structure, compatibility of performance indices, and engineering support. Based on the three criteria and our solution's efficiency indicators, the energy initiatives of Customer (Winchester) have been analyzed and possible energy efficiency improvement opportunities have been found. The results of this case study indicated the significant potential for the application of our energy management technology and energy saving projects at other Newell-Customer facilities.

Source:

Installation and Metering Test Equipment:

- Dent Industries Power Quality Meter, Model No. ElitePRO XC, Serial No. XC1307109 (Calibrated by U.S. Calibration, Aug. 2013) Attached
- ITRON KVA Meter, Model SS3S4L, Serial Number 53120705 (Calibrated by Powermetrix, Feb. 20, 2014) Attached
- Mastech Power Quality Handheld Meter
- Xeco Engineering Protocol Software

Software: ELOG Data Logger Software (Version

ELOG 13) Xeco Engineering Test Parameters:

Setup Table Description: 3-Phase, 3-Wire

Memory Type: Ring

Line Frequency: 60 Hertz

Integration Period: 1 Second

Logger Description Line: Dent ELITEpro XC; Serial No. XC1307109

(Calibration Trace: National Institute of Standards and Technology (NIST)

Instruments: Hewlett-Packard 34401A, Serial #: US36141163

Hewlett-Packard 34401A, Serial #: MY41039517

Logger Serial No.: XC1307109

Logger Type: ELITEpro XC

Firmware: ES400.226

Peak Demand Minutes: 15 Minutes

Current Transformer (CT)

Power 1: Power: VHi: L1, VLo: N; PT=1.000; CT=5000.000; CT

Type=ROCOIL; Phase Shift=0.000

Power 2: Power: VHi: L2, VLo: N;

PT=1.000; CT=5000.000; CT Type=ROCOIL; Phase Shift=0.000

Power 3:

Power: VHi: L3, VLo: N; PT=1.000; CT=5000.000; CT Type=ROCOIL; Phase Shift=0.000

Power 5:

Power Sum: 1, 2, 3

Utility Meter Specifications:

Meter Type: ITRON Sentinel Form 5S Meter (Meter Specifications Attached)

Provider: Shenandoah Valley Electric Cooperative

Model No.: SS3S4L (Powermetrix Load Meter Calibration Test Attached)

Serial No.: 53120705


Meter No.: 53120705

Project Manager: 


**Gregory A. Dockery, CEO/Project Manager**  
*Member: IEEE and IEEE-SA (Standards Association)*

Engineering Review: 

**B.M. Wu, PhD., E.E.**

Engineering Review: 

**M. Timothy Orth, M.S., E.E.**

Engineering Review: 

**Marc A. Ramirez, P.E.**